



U.S. DEPARTMENT OF
ENERGY

THIS
HOME'S
SCORE **5**
OUT OF 10

THIS HOME'S ESTIMATED
ENERGY COSTS

\$1,697
PER YEAR

HOME PROFILE

LOCATION:

3018 SE 169th Ave
Portland, OR 97236

YEAR BUILT:

1965

HEATED FLOOR AREA:

1,439 sq.ft.

NUMBER OF BEDROOMS:

3

ASSESSMENT

ASSESSMENT DATE:

08/20/2019

SCORE EXPIRATION DATE:

08/20/2027

ASSESSOR:

Alex Albright
Order Home Energy Score.com
LLC

PHONE:

503-543-1111

EMAIL:

contact@
orderhomeenergyscore.com


LICENSE #:

218360

*Flip over to learn how
to improve this score
and use less energy!*



Home Energy Score



Official Assessment | ID# 289808

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.

HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

Electric: 9,235 kWh/yr. \$1,016

Natural Gas: 0 therms/yr. \$0

Other: \$681

Renewable Generation: (\$0)

TOTAL ENERGY COSTS PER YEAR \$1,697

How much
**renewable
energy** does
this home
generate?

____ kWh/yr

THIS HOME'S CARBON FOOTPRINT:



What should my home's carbon footprint be? Between now and 2030, Portlanders should reduce carbon pollution per household to 3 metric tons per year to reach our climate goals.

- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices (\$0.11/kwh for electricity; \$0.99/therm for natural gas; \$2.58/gal for heating oil; \$2.21/gal for propane).
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- Relisting 2-7 years after the assessment date requires a free reprint of the Report from us.greenbuildingregistry.com to update energy and carbon information.
- **This report meets Oregon's Home Energy Performance Score Standard and complies with Portland City Code Chapter 17.108.**

Score
today:

5

Score with priority
improvements:

8

Estimated **energy savings**
with priority improvements:

\$288 PER
YEAR

Estimated **carbon reduction**
with priority improvements:

17% PER
YEAR

TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- ☒ Get your home energy assessment. Done!
- ☐ Choose energy improvements from the list of recommendations below.
- ☐ Select a contractor (or two, for comparison) and obtain bids.
Checkout www.energytrust.org/findacontractor or call toll free **1-866-368-7878**.
- ☐ Explore financing options at communityenergyproject.org or energytrust.org.
- ☐ Visit the following resources to learn about easy changes you can make today: communityenergyproject.org/services or energytrust.org/solutions/insulation-and-air-sealing/

PRIORITY ENERGY IMPROVEMENTS | 10 YEAR PAYBACK OR LESS ¹

FEATURE	TODAY'S CONDITION ³	RECOMMENDED IMPROVEMENTS
Floor insulation	Insulated to R-0	Insulate to R-30 or fill floor cavity
Water Heater	Electric	When replacing, upgrade to ENERGY STAR, minimum 2.76 EF (Energy Factor)

ADDITIONAL ENERGY RECOMMENDATIONS ²

FEATURE	TODAY'S CONDITION ³	RECOMMENDED IMPROVEMENTS
Attic insulation	Ceiling insulated to R-25	Insulate to R-38 or R-49 if code requires it
Duct sealing	Un-sealed	Reduce leakage to a maximum of 10% of total airflow
Envelope/Air sealing	Not professionally air sealed	Professionally air seal
Solar PV	N/A	Visit www.energytrust.org/solar to learn more
Wall insulation	Insulated to R-0	Fully insulate wall cavities
Air Conditioner	N/A	
Basement wall insulation	N/A	
Cathedral Ceiling/Roof	None	
Duct insulation	Un-insulated	
Foundation wall insulation	N/A	
Heating equipment	Oil furnace 85% AFUE	
Skylights	N/A	
Windows	Double-pane, low-E glass	

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. These priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. If your home has an oil furnace it is recommended you replace it with a high efficiency electric heat pump.

4. Today's Condition represents the majority condition for that feature in the home.